



Ref. Certif. No.

AT 5199

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Grid connected photovoltaic inverter

Name and address of the applicant

Fronius International GmbH
Froniusstraße 1,
4643 Pettenbach, Austria

Name and address of the manufacturer

Fronius International GmbH
Froniusstraße 1,
4643 Pettenbach, Austria

Name and address of the factory

Fronius International GmbH
Fronius Straße 5,
4642 Sattledt, Austria

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2
see page 2

Ratings and principal characteristics

Trademark / Brand (if any)

FRONIUS

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Symo GEN24 10.0 Plus SC, Symo GEN24 10.0 SC,
Symo GEN24 9.0 Plus SC, Symo GEN24 9.0 SC,
Symo GEN24 8.0 Plus SC, Symo GEN24 8.0 SC,
Symo GEN24 7.0 Plus SC, Symo GEN24 7.0 SC,
Symo GEN24 6.0 Plus SC, Symo GEN24 6.0 SC

Additional information (if necessary may also be reported on page 2)

--
☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61000-3-2:2018 IEC 61000-6-2:2016
IEC 61000-3-3:2013 IEC 61000-6-3:2020
IEC 61000-3-3:2013/AMD1:2017 IEC 61000-6-4:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

2024-AT-TC-EEE-1-EX-0-000209-EMV-001,
2024-AT-TC-EEE-1-EX-0-000209-EMV-002,
2024-AT-TC-EEE-1-EX-0-000209-EMV-003,
2024-AT-TC-EEE-1-EX-0-000209-EMV-004

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

OVE Certification

Kahlenberger Str. 2A, 1190 Wien, Austria

T. Neumayer

Digitally signed by T. Neumayer
Email: t.neumayer@ove.at



Date: 2025-02-03

Signature: Dipl.-Ing. T. Neumayer

Ratings:

Symo GEN24 10.0 Plus SC, Symo GEN24 10.0 SC:
220/380 V 15.2 A, 230/400 V 14.5 A

Symo GEN24 9.0 Plus SC, Symo GEN24 9.0 SC:
220/380 V 13.6 A, 230/400 V 13.0 A

Symo GEN24 8.0 Plus SC, Symo GEN24 8.0 SC:
220/380 V 12.1 A, 230/400 V 11.6 A

Symo GEN24 7.0 Plus SC, Symo GEN24 7.0 SC:
220/380 V 10.6 A, 230/400 V 10.1 A

Symo GEN24 6.0 Plus SC, Symo GEN24 6.0 SC:
220/380 V 9.1 A, 230/400 V 8.7 A

Additional information (if necessary)

Date: 2025-02-03


Digitally signed by T. Neumayer
Email=t.neumayer@ove.at
Signature: Dipl.-Ing. T. Neumayer