Ref. Certif. No.

NL-126865

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Hybrid Inverter
Name and address of the applicant	GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China
Name and address of the manufacturer	GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China
Name and address of the factory	GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China
When more than one factory	☒ Additional information on page 3
Ratings and principal characteristics	**Product data** Ratings: Operating temperature range: - 35°C to + 60°C Protective class: I, Ingress protection rating: IP66 Power factor range (adjustable): 0,8 leading ~ 0,8 lagging Altitude (m): 4000, PV input: max 1000 Vdc GW5K-ET-L-G10: Max, Input Power: 10 kW, AC Side Nominal Power: 5 kW, Max Output Apparent Power: 5,5 kVA GW6K-ET-L-G10: Max, Input Power: 12 kW, AC Side Nominal Power: 6 kW, Max Output Apparent Power: 6,6 kVA GW8K-ET-L-G10: Max, Input Power: 16 kW, AC Side Nominal Power: 8 kW, Max Output Apparent Power: 8,8 kVA GW10K-ET-L-G10: Max, Input Power: 20 kW, AC Side Nominal Power: 10 kW, Max Output Apparent Power: 11 kVA GW12K-ET-L-G10: Max, Input Power: 24 kW, AC Side Nominal Power: 12 kW, Max Output Apparent Power: 13,2 kVA GW15K-ET-L-G10: Max, Input Power: 30 kW, AC Side Nominal Power: 15 kW, Max Output Apparent Power: 16,5 kVA GW20K-ET-L-G10: Max, Input Power: 40 kW,

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-18

Signature: May Liu

Ref. Certif. No.

NL-126865

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

	AC Side Nominal Power: 20 kW, Max Output Apparent Power: 22 kVA GW12K-ET-LL-G10: Max, Input Power: 24 kW, AC Side Nominal Power: 12 kW, Max Output Apparent Power: 13,2 kVA
Trademark / Brand (if any)	GOODWE
Customer's Testing Facility (CTF) Stage used	CTF Stage 1
Model / Type Ref.	GW10K-ET-L-G10, GW12K-ET-L-G10, GW12K-ET-LL-G10, GW15K-ET-L-G10, GW20K-ET-L-G10, GW5K-ET-L-G10, GW6K-ET-L-G10 and GW8K-ET-L-G10
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62109-1:2010 and IEC 62109-2:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	6267687.50(A-B)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-18

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

GoodWe (GuangDe) Power Supply Technology Co., Ltd.
No.208, Tong Rui East Road, Guangde, Anhui, 242200, China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-18

Signature: May Liu