

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50735307 0001

Berichtsnummer Report No.:

CN26XCMR 001

Genehmigungsinhaber License Holder:

GoodWe Technologies Co., Ltd.

No.90 Zijin Rd., New District

215011 Suzhou

P.R. China

Fertigungsstätte Manufacturing Site:

2 Fertigungsstätten auf Folgeseiten

Listing of 2 factories on following pages
Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN 61439-1:2011

EN 61439-2:2011

IEC 61439-1:2011

IEC 61439-2:2011

Geräteidentifikation
Product Identification
Produkt: Distributer Cabinet

Product: (PV Static Transfer Switch)

Modell: Modelle sind auf nächste(r) Seite(n) gelistet

Type: *Type designation(s) are listed on the next page(s)*
Technische Daten: Refer to the next page (s)

Technical Data: ANLAGE (Appendix): 1.0

Gültig ab: 2026-07-01

Valid from:
Zertifizierungsstelle:
Certification body:
Ausstellungsdatum: 2026-07-01

Date of issue:

Bowen Dong



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

TÜVRheinland®
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50735307 0001

Berichtsnummer *Report No.:*

CN26XC MR 001

Produkt *Product:* Distributer Cabinet
(PV Static Transfer Switch)

Modell *Type:* **Bezeichnung** *Designation:*

- 1) GW30K-ST S-G10 ,
- 2) GW60K-ST S-G10

Inverter port

 Rated Voltage [Va.c.] : 3L/N/PE, 220/380,
230/400, 240/415

Rated Frequency [Hz] : 50/60

Max. Input Current [Aa.c.] : 1)63, 2)63

Smart-port

 Rated Voltage [Va.c.] : 3L/N/PE, 220/380,
230/400, 240/415

Rated Frequency [Hz] : 50/60

Max. Current [Aa.c.] : 1)63, 2)100

Back-up port

 Rated Voltage [Va.c.] : 3L/N/PE, 220/380,
230/400, 240/415

Rated Frequency [Hz] : 50/60

Max. Output Current [Aa.c.] : 1)63, 2)100

Grid port

 Rated Voltage [Va.c.] : 3L/N/PE, 220/380,
230/400, 240/415

Rated Frequency [Hz] : 50/60

Max. Current [Aa.c.] : 1)63, 2)100

General

Protective Class : Class I

Degree of Protection : IP54

Pollution Degree (PD) : PD3(Outside), PD2(Inside)

Altitude[m] : ≤4000

Operating Temperature [°C] : -35 to 60°C

Overvoltage Category : III



Remark(s):

The installation has to be carried out according to the installation instruction specified by the manufacturer. Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
R 50735307 0001

Berichtsnummer *Report No.:*
CN26XCMR 001

Produkt *Product:*
Distributer Cabinet (PV Static Transfer Switch)

Fertigungsstätten *Factories:*

- 1 GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China
- 2 GoodWe (GuangDe) Power Supply
Technology Co., Ltd.
No. 208, Tong Rui East Road
Guangde
Anhui
P.R. China

