

Ginlong Energy Storage Co., Ltd.

Date : 20 January, 2026
Our ref. : 326133613
Your ref. : 245884650

No.57 Jintong Road, Binhai Industrial Park, DongChen,
Xiangshan.315712 Ningbo, Zhejiang, PEOPLE'S
REPUBLIC OF CHINA

Dear Mr. Ruyi Pan,

We herewith notify that the product: **Rechargeable Li-ion Battery System**

Type designation: EverCore-99.9kWh, EverCore-100kWh, EverCore-120kWh,
EverCore-99.9kWh-PRO, EverCore-100kWh-PRO, EverCore-
120kWh-PRO

has been inspected against the following requirement(s)

Test requirement: **PGS 37-1: 2023**

Only for typical 1-Stand-alone EOS in (adapted) containers:

The following measures are found to meet the relevant requirements of the standards:

M3, M4, M5, M8, M31, M33, M34, M35, M36, M37, M38, M39, M40, M42, M44, M48, M64, M65, M66;

The following measures have not been evaluated and the reasons:

1. M2, reason: ESS has not been certified in accordance with IEC 62933-5-2;
2. M9, M18, M55, reason: ESS did not conduct fire propagation tests based on IEC 62933-5-2 or UL9540A;
3. M32, reason: Only H2 detectors are equipped, and CO detectors are not provided simultaneously;

We appreciate your valued support and would like to offer our assistance and varied services in the approval of your products in the future.

With kind regards,

TÜV Rheinland (Shanghai) Co., Ltd.

Stone Wang

Stone Wang (Section Manager)
Solar & Commercial Products Greater China