



## Type Examination Certificate

(1)

(2)

Equipment or Protective Systems Intended for Use  
in Potentially Explosive Atmospheres  
(Directive 2014/34/EU)

(3) Type Examination Certificate number:

**FTZÚ 17 ATEX 0027X**

(4) Product: **Luminaire type SALUKA-N-LED; MULTISALUKA-N-LED and SALUKA-N-Em-LED**

(5) Manufacturer: **VYRTYCH a.s**

(6) Address: **Židněves 116, 294 06 Březno, Czech Republic**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) The Physical-Technical Testing Institute certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to Directive 2014/34/EU of the European Parliament and of the Council, dated 26.02.2014.

The examination and test results are recorded in confidential Report number:

**17/0027 dated 09.05.2017**

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0:2012, EN 60079-15:2010, EN 60079-31:2014**

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to Specific Conditions of Use specified in the schedule to this certificate.

(11) This type examination certificate relates only to the design of the specified product and not to specific items of equipment subsequently manufactured.


(12) The marking of the product shall include the following:

 **II 3G Ex nR IIC T6 Gc**

 **II 3D Ex tc IIIC T65°C Dc**

This certificate is valid till: **30.04.2022**

Responsible person:

  
Dipl. Ing. Lukáš Martinák  
Head of Certification Body



Date of issue: 10.05.2017

Page: 1/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.  
This certificate may only be reproduced in its entirety and without any change, schedule included.



Physical-Technical Testing Institute  
Ostrava - Radvanice

(13)

Schedule

(14)

Type Examination Certificate No. FTZÚ 17 ATEX 0027X

(15) Description of Product:

The type SALUKA-N-LED, SALUKA-N-Em-LED (non-maintained emergency lighting) and MULTISALUKA-N-LED (maintained emergency lighting) luminaire with degree of protection IP 66 is composed of three parts: body with exchangeable sealing from varnished or stainless steel plate and glass light-transmitting cover from safety toughened glass and varnished steel plate (reflector) with electrical package.

The body and optical cover are connected by steel clips with locking screws. The body is equipped by Ex-cable glands (resp. Ex-blanking elements).

On the reflector are installed three-pole terminal block WAGO for connection of power cable with wires to 2,5mm<sup>2</sup>, LED drivers or emergency units and battery pack type VBA-N.

As the light sources are used LED modules which are fixed on the reflector.

Electrical parameters:

Nominal Voltage: 220-240V AC; 0/50/60Hz or 110-240V AC; 50/60Hz;  
220-240V DC

TYPE CODING OF LUMINAIRE:

Type coding	Type
SALUKA – N- LED – X*YYY*- 4K	A type luminaire - standard lighting
MULTISALUKA – N- LED – X*-YYY*- 4K	A type luminaire - maintained emergency lighting
SALUKA – N- Em - LED – X*-YYY*- 4K	A type luminaire - non-maintained emergency lighting

- X\* - marking of luminous flux (lm)
- YYY\* - marking of type body of luminaire
- 4K - colour temperature (K)

(16) Report Number.: 17/0027

Responsible person:

  
Dipl. Ing. Lukáš Martinák  
Head of Certification Body



Date of issue: 10.05.2017

Page: 2/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.  
This certificate may only be reproduced in its entirety and without any change, schedule included.



Physical-Technical Testing Institute  
Ostrava - Radvanice

(13)

Schedule

(14)

Type Examination Certificate No. FTZÚ 17 ATEX 0027X

(17) Specific Conditions of Use:

1. Ambient temperature range:  $-20^{\circ}\text{C} \leq T_{\text{amb}} \leq +60^{\circ}\text{C}$  – SALUKA-N-LED-5000-236-4K  
 $-20^{\circ}\text{C} \leq T_{\text{amb}} \leq +45^{\circ}\text{C}$  – SALUKA -N-LED-2500/7500-218/258-4K  
 $-20^{\circ}\text{C} \leq T_{\text{amb}} \leq +45^{\circ}\text{C}$  – SALUKA -N-LED-5000/10000-218/236-4K  
 $-20^{\circ}\text{C} \leq T_{\text{amb}} \leq +40^{\circ}\text{C}$  – SALUKA -N-LED-12550-258-4K  
 $0^{\circ}\text{C} \leq T_{\text{amb}} \leq +45^{\circ}\text{C}$  – MULTISALUKA-N-LED-5000-236-4K  
 $0^{\circ}\text{C} \leq T_{\text{amb}} \leq +40^{\circ}\text{C}$  – MULTISALUKA-N-LED-2500/7500-218/258-4K  
 $0^{\circ}\text{C} \leq T_{\text{amb}} \leq +50^{\circ}\text{C}$  – SALUKA-N-Em-LED-500-218/236/258-4K.
2. The luminaire is intended for fixed installation and must be labelled "Warning - potential danger of electrostatic charging" - see Technical conditions.
3. The power supply cable shall be effectively fixed to prevent pulling or twisting.
4. The Technical conditions of maintenance must be complied

(18) Essential Health and Safety Requirements:

Compliance with the Essential Health and Safety Requirements is covered by standards mentioned in clause (9) of this certificate.

(19) Drawings and Documents:

Number	Sheets	Issue	Date	Description
--	7	00	04.05.2017	Technical description
--	2	00	03.05.2017	Technical conditions for mounting
Assembly	1	--	04.01.2017	Drawing
Labels	2	02	03.05.2017	Drawing

Responsible person:

  
Dipl. Ing. Lukáš Martinák  
Head of Certification Body



Date of issue: 10.05.2017

Page: 3/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.  
This certificate may only be reproduced in its entirety and without any change, schedule included.